TROUBLE SHOOTING

Instructions relating to heating (*) are applicable only to "HEAT & COOL MODEL" (Reverse Cycle). Before requesting service, perform the following checks:

	Symptom	Cause and Action				
NORMAL FUNCTION	Doesn't operate immediately.	 If the unit is stopped and then immediately started again, the compressor will not oper about 3 minutes, in order to prevent fuse blowouts. Whenever the electrical breaker is turned off them on again, the protection circuit will of or about 3 minutes, preventing unit operation during that period. 				
	Noise is heard.	 During operation and immediately after stopping the unit, the sound of water flowing in the air conditioner's piping may be heard. Also, noise may be particularly noticeable for about 2 to 3 minutes after starting operation (sound of coolant flowing). During operation, a slight squeaking sound may be heard. This is the result of minute expansion and contraction of the front cover due to temperature changes. 				
		•*During Heating operation, a sizzling sound may be heard occasional. This is produced by the Automatic Defrosting operation.				
		• During stop mode, sibilant sound may be heard. This is due to a small amout of refrigeran being put through a piping and is not a malfunction.				
	Smells.	Some smell may be emitted from the indoor unit. This smell is the result of room sr (furniture, tobacco, etc.) which have been taken into the air conditioner.				
	Mist or steam are emitted.	During Cooling operation or Dry operation, a thin mist may be seen emitted from the indoor unit. This results from the sudden cooling of room air by the air emitted from the air conditioner, resulting in condensation and misting.				
		•*During Heating operation, the outdoor unit's fan may stop, and steam may be sent rising from the unit. This is due to Automatic Defrosting operation.				
	Airflow is weak or stops.	*When Heating operation is started, indoor unit's fan may temporarily stop to allow internal parts to warm up. *During Heating operation, if the room temperature rises above the set temperature, the outdoor unit will stop, and the indoor unit's fan will stop. If you wish to warm the room further, set the temperature for a higher setting.				
		•*During Heating operation, the unit will temporarily stop operation (between 2 and 16 minutes) as the Automatic Defrosting mode operates. During Automatic Defrosting operation, the OPERATION indicator will flash.				
		The fan may operate at very low speed during Dry operation or when the unit is monitoring the room temperature.				
		In the monitor AUTO operation, the fan will operate at very low speed.				
	Water is produced from the outdoor unit.	•*During Heating operation, water may be produced from the outdoor unit due to Automatic Defrosting operation.				
CHECK ONCE MORE	Doesn't operate at all.	 Has there been a power failure? Has a fuse blown out, or a circuit breaker been tripped? Is the main power switch set to the OFF position? 				
		Is the timer operating?				
	Poor Cooling (or *Heating) performance.	 Is the air filter dirty? Are the air conditioner's intake grille or outlet port blocked? Is there a window or door open? In the case of Cooling operation, is a window allowing bright sunlight to enter? (Close the curtains.) In the case of cooling operation, are there heating apparatus and computers inside the room or are there too many people in the room? 				
	The unit operates differently from the remote controller's setting.	Are the remote controller's batteries dead? Are the remote controller's batteries loaded properly?				

If the problem persists after performing these checks, or if you notice burning smells, or the TIMER indicator flashes, immediately stop operation, turn off the electrical breaker and consult authorized service personnel.

SPECIFICATIONS

MODEL		AR□7UF	AR□9UF	AR□12UF	AR□14UF	AR□18UF	AR□22UF		
POWER		220 - 240 V ~ 50 Hz							
COOLING CAPACITY [kW]		2.15	2.80	3.50	4.00	5.30	6.00		
HAEATING CAPACITY [kW]		2.45	3.10	4.10	4.80	5.60	6.30		
DIM	DIMENSION & WEIGHT								
	HEIGHT [mm]		217						
	WIDTH [mm]		663		953				
	DEPTH [mm]		595						
	WEIGHT [kg]		18		25				

Acoustic Noise Information: The maximum sound pressure level is less than 70 dB (A) for both indoor unit and outdoor unit. According to IEC 704-1 and ISO 3744.



KEEP THIS OPERATING MANUAL FOR FUTURE REFERENCE

EEE Yönetmeliğine Uygundur.



DUCT TYPE

CEILING CONCEALED

PART NO. 9373667018-02 English
FUJITSU GENERAL LIMITED

OPERATING MANUAL

SAFETY PRECAUTIONS

Before using the appliance, read these "PRECAUTIONS" thoroughly and operate in the correct way. The instructions in this section all related to safely; be sure to maintain safe operating conditions.

⚠ DANGER!

This mark indicates procedures which, if improperly performed, are most likely to result in the death of or serious injury to the user or service personnel.

- Do not attempt to install this air conditioner by yourself.
- This unit contains no user-serviceable parts. Always consult authorized service personnel for repairs.
- When moving, consult authorized service personnel for disconnection and installation of the unit.
- Do not become overexposed to cold air by staying in the direct path of the airflow of the air conditioner for extended periods of time.
- Do not insert fingers or objects into the outlet port or intake grilles.
- Do not start and stop air conditioner operation by turning off the electrical breaker or disconnecting the power supply plug and so on.
- Take care not to damage the power supply cord.

⚠ WARNING!

This mark indicates procedures which, if improperly performed, might lead to the death or serious injury of the user.

 If a problem (burning smell, etc.) occurs, turn off the electrical breaker immediately to stop operation, and then consult an authorized service personnel. • Merely turning off the unit's power switch will not completely disconnect the unit from the power source. Always be sure to turn off the electrical breaker to ensure that power is completely off.

A CAUTION!

This mark indicates procedures which, if improperly performed, might possibly result in personal harm to the user, or damage to property.

- Provide occasional ventilation during use.
- Do not install and direct air flow at fireplaces or heating apparatus.
- \bullet Do not climb on, or place objects on, the air conditioner.
- Do not hang objects from the indoor unit.
- Do not set flower vases or water containers on top of air conditioners.
- Do not expose the air conditioner directly to water.
- Do not operate the air conditioner with wet hands.
- Do not pull the power supply cord.
- Turn off power source when not using the unit for extended periods.
- Always turn off the electrical breaker whenever cleaning the air conditioner or the air filter.
- When removing and replacing the air filters, be sure not to touch the heat exchanger, as personal injury may result.
- Take care to prevent infants from accidentally swallowing batteries.
- When not using the remote controller for an extended period, remove the batteries to avoid possible leakage and damage to the unit.
- If leaking battery fluid comes in contact with your skin, eyes, or mouth, immediately wash with copious amount of water, and consult your physician.

- Dead batteries should be removed immediately and disposed of properly, either in a battery collection receptacle or to the appropriate authority.
- Do not attempt to recharge dry batteries.
- Connection valves become hot during Heating; handle with care.
- Check the condition of the installation stand for damage.
- Do not place animals or plants in the direct path of the air flow.
- When restarting after a long period of disuse in winter, do; Turn the power switch on at least 12 hours before starting the unit.
- Do not drink the water drained from the air conditioner.
- Do not use in applications involving the storage of foods, plants or animals, precision equipment, or art works.
- Do not apply any heavy pressure to radiator fins.
- Operate only with air filters installed.
- Do not block or cover the intake grille and outlet port.
- Ensure that any electronic equipment is at least one meter away from either the indoor or outdoor units.
- When installing the indoor and outdoor unit, take precautions to prevent access to infants.
- Do not use inflammable gases near the air conditioner.

OPERATING TIPS

Heating performance

- This air conditioner operates on the heat-pump principle, absorbing heat from outdoor air and transferring that heat indoors. As a result, the operating performance is reduced as outdoor air temperature drops.
 If you feel that insufficient heating performance is being produced, we recommend you use this air conditioner in conjunction with another kind of heating appliance.
- Heat-pump air conditioners heat your entire room by recirculating air throughout the room, with the result that some time may by required after first starting the air conditioner until the room is heated.

Cooling / heating priority (J series only)

- If another indoor unit in the same system is already operating in the cooling mode or dry mode, heating mode settings cannot be performed.
- If another indoor unit in the same system is already operating in the heating mode, cooling mode or dry mode settings cannot be performed.

Oil recovery operation

Periodically, the oil recovery operation is performed in order to return compressor oil to the outdoor unit. Operation is stopped during this oil recovery operation. During oil recovery operation, the OPERATION indicator (red) will flash.


Microcomputer-controlled Automatic Defrosting

When using the Heating mode under conditions of low outdoor air temperature high humidity, frost may form on the outdoor unit, resulting in reduced operating performance. In order to prevent this kind of reduced performance, this unit is equipped with a Microcomputer-controlled Automatic Defrosting function. If frost forms, the air conditioner will temporarily stop, and the defrosting circuit will operate briefly (for about 2 to 16

During Automatic Defrosting operation, the OPERATION indicator (red) will flash.


PREPARATION

LOAD BATTERIES (R03/LR03 x 2)



- 1. Press and slide the lid.
- 2. Insert batteries.
- Be sure to follow the polarity markings indicated in the compart-
- 3. Slide back the lid.

SET THE CURRENT TIME




- 1. Press the TIME ADJUST button.
- 2. Press the (+) / (-) button.
- 3. Press the TIME ADJUST button.

REMOTE CONTROLLER HOLDER



To set the remote controller in the holder

- 1. Insert.
- 2. Press in.




To take out the remote controller from the <u>holder</u>

- 1. Slide up.
- 2. Pull out.

MANUAL AUTO OPERATION

Use the MANUAL AUTO operation when the remote controller is lost or unavailable.




Press the MANUAL AUTO (1/0) button on the receiver unit control panel.

To stop operation, press the MANUAL AUTO (1/0) button again.


I NOTES

- Each press of the MANUAL AUTO button alternates operation and stop.
- When the air conditioner is operated from the main unit, "HEAT & COOL MODEL" will operate COOL or HEAT. "COOLING ONLY MODEL" will operate AUTO.
- The fan speed is selected to "AUTO" and the temperature setting will be set to 23 °C.



1111

I NOTES Temperature setting range AUTO • • • • • • 18 to 30 °C HEAT •••••• 16 to 30 °C COOL/DRY • • • 18 to 30 °C The thermostat setting should be considered a stan-dard value, and may differ somewhat from the actual room temperature.






Press the button.

Select ②▶፟ (TIMER RESET).

Press the button while in operation.

The air conditioner will return to normal operation.



Reciever unit

i NOTES

- (1) The remote controller must be pointed at the receiver unit to operate correctly.
- (2) Operating range: About 7 meters.

Each press of the button alternates

(3) Beeping sound

START/STOP

operation and stop.

- When a signal is properly received by the air conditioner, a beeping sound will be heard twice.
- If an invalid signal is received by the air conditioner, a beeping sound will be heard 5 times.
- If no beeping sound is heard, press the remote controller button again.
- (4) The buttons except the SLEEP, TIME ADJUST and ACL buttons can only be selected while in operation mode.
- The PROGRAM timer allows you to integrate OFF timer and ON timer operations in a single sequence.
- The first timer function to operate will be the one set nearest to the current time.
- (6) SLEEP timer


To prevent excessive warming or cooling during sleep, the SLEEP timer function automatically modifies the set temperature in accordance with the time setting. When the set time has elapsed, the air conditioner completely stops.

- (7) When connecting with other remote controllers, the indoor unit might be controlled by the other remote controllers.
- (8) The wired remote controller or the simple remote controller can also be used with this unit.

CLEANING AND CARE

INSTALLING THE AIR FILTER

Be sure the filter is always installed in the inlet air grille of the indoor unit.



I NOTES

The filters can be purchased through your local dealer.

CLEANING THE AIR FILTER

Use a vacuum cleaner to remove dust and dirt from the air filter, or wash in a synthetic detergent. After washing, dry in a shaded place, then reinstall.

i NOTES

@+⊠

- When used for extended periods, the unit may accumulate dirt inside, reducing its performance. We recommend that the unit be inspected regularly, in addition to your own cleaning and
- For more information, consult authorized service personnel.
- When cleaning the unit, do not use water hotter than 40 °C, harsh abrasive cleansers, or volatile agents like benzene or thin-
- Do not expose the unit to liquid insecticides or hairsprays.
- During periods of normal use, the air filters should be cleaned every two weeks
- When shutting down the unit for one month or more, first allow the fan mode to operate continuously for about one-half day to allow internal parts to dry thoroughly.